

COMMONWEALTH OF KENTUCKY
BEFORE THE PUBLIC SERVICE COMMISSION

In the Matter of:

THE APPLICATION OF GARRISON-QUINCY-KY-O-)	
HEIGHTS WATER DISTRICT FOR A DEVIATION)	CASE NO.
FROM THE REQUIREMENTS OF 807 KAR 5:066,)	2003-00418
SECTION 4(4), REGARDING WATER STORAGE)	

O R D E R

On November 7, 2003, the Garrison-Quincy-Ky-O-Heights Water District ("Garrison-Quincy District") applied for permission to deviate from Administrative Regulation 807 KAR 5:066, Section 4(4), which requires that each utility maintain minimum water storage of one day's supply of its average daily usage. Garrison-Quincy District states in its application that its average daily water usage, including unaccounted-for water, is approximately 154,000 gallons; however, the 2002 annual report shows this number to be approximately 188,000 gallons and that its current water storage capacity is 150,000 gallons. Vanceburg Electric Plant Board, Garrison-Quincy District's current water supplier, has a 268,000-gallon water storage tank located within 1,000 feet from the master meter.

The Commission, having reviewed the application and being otherwise sufficiently advised, finds that:

1. Garrison-Quincy District is not in compliance with Administrative Regulation 807 KAR 5:066, Section 4(4).
2. Because of the time needed to plan, finance, and construct water storage facilities, Garrison-Quincy District should be given until January 1, 2008 to comply with Administrative Regulation 807 KAR 5:066, Section 4(4).

IT IS THEREFORE ORDERED that:

1. Garrison-Quincy District is given until January 1, 2008 to comply with the provisions of Administrative Regulation 807 KAR 5:066, Section 4(4).

2. Garrison-Quincy District shall take all necessary actions to bring its water storage facilities into compliance with Commission regulations prior to January 1, 2008.

Done at Frankfort, Kentucky, this 24th day of December, 2003.

By the Commission

ATTEST:


Executive Director

Case No. 2003-00418